

Environmental Claim Validation

Certificate

77508-4170

Issue Date

28 Mar 2016

Expiration Date

28 Mar 2027



Ranee Valles
Director and General Manager

UL Verification Services Inc.
2211 Newmarket Parkway, ste 106
Marietta, GA 30067 USA

UL Verification Services does hereby certify that an independent assessment has been conducted on behalf of:

Dalsan Alci Sanayi VE Ticaret A.S

for the following product:

BoardeX roof

The product has been evaluated and meets the requirements for:

Claim:

BoardeX Roof resisted fungal growth as tested by ASTM D3273 and meets the requirements of UL 2282 for being Resistant to BSL1 Fungal Growth

Method:

Environmental Claim Validation Procedure (ECVP) for Resistance to Microbial Growth, UL ECVP 2282-Edition 4.0, dated December 29, 2023

Facility:

Ankara

UL Solutions evaluated representative samples of the identified product, process or facility to the identified Standard or other requirements in accordance with the agreements and any applicable program service terms in place between UL Solutions and the Client (collectively "Agreement"). The Client is authorized to use the UL Mark for the identified Product, process or facility covered by this certificate, in accordance with the terms of the Agreement. This Certificate is valid for the identified dates unless there is non-compliance with the Agreement. This certificate is subject to modification, suspension and withdrawal by UL Solutions see SPOT.ul.com, to authenticate the certificate.